



QUALITY CONTROL DISTRICT LABORATORY KERALA WATER AUTHORITY

Vellayambalam, Thiruvananthapuram – 695033
Tel: 04712992303; e-mail: aeqcdltvm@gmail.com



TEST REPORT

ULR No: TC1216426000001722F

Test Report No: 2026/QCDL/TVM/1722

Date: 16.05.2026

Customer Name & Address: NAVAJEEVAN BETHANY VIDYALAYA, NALANCHIRA P O TVPM.

Phone Number : 9495407382

Date of collection : 11.05.2026

Sampling was done by: The Customer (QUA_334323)

Sample code: 2026/QCDL/TVM/1722

Sample particulars: Drinking Water

Sample quantity: 2 Litres

Date of analysis: From: 12.05.2026 To: 15.05.2026

Sl. No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Colour	Pt Co. Units	IS 3025 (Part 4), Platinum Cobalt Visual comparison	5	10
2	Electrical Conductivity	micro mhos/cm	IS 3025 (Part 14)	-	67.48
3	pH		IS 3025 (Part 11), Electrometric Method	6.5 to 8.5	6.69
4	Turbidity	NTU	IS 3025 (Part 10), Nephelometric Method	1	3.46

BDL=Below Detection Limit; DL=Detection Limit

Remarks:

- The results apply to the sample as received for testing.
- This test report shall not be reproduced except in full without the written approval of the laboratory management.
- The retention period of the sample is five days from the date of analysis.



Analyzed by

Authorized Signatory

(SEENA H)

End of the report

SANITARY CHEMIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
THIRUVANANTHAPURAM



QUALITY CONTROL DISTRICT LABORATORY KERALA WATER AUTHORITY

Vellayambalam, Thiruvananthapuram – 695033
Tel: 04712992303; e-mail: aeqcdltvm@gmail.com



TEST REPORT

ULR No: TC1216426000001722F

Test Report No: 2026/QCDL/TVM/1722

Date: 16.05.2026

Customer Name & Address: NAVAJEEVAN BETHANY VIDYALAYA, NALANCHIRA P O TVPM.
Phone Number : 9495407382

Date of collection: 11.05.2026

Sampling was done by: The Customer (QUA_334323)

Sample code: 2026/QCDL/TVM/1722

Sample particulars: Drinking Water

Sample quantity: 250 ml

Date of analysis: From: 11.05.2026 To: 12.05.2026

Sl. No	Parameters	Acceptable limits as per IS-10500-2012	Test Method	Result
1	Total Coliform	Shall not be detected / 100ml	IS 15185 Membrane Filtration Method	ABSENT / 100 ml
2	<i>E. coli</i>	Shall not be detected / 100ml	IS 15185 Membrane Filtration Method	ABSENT / 100 ml

Remarks:

1. The results apply to the sample as received for testing.
2. This test report shall not be reproduced except in full without the written approval of the laboratory management.



Analyzed by

End of the report

Authorized Signatory

BACTERIOLOGIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
THIRUVANANTHAPURAM